



SGS Portugal, S.A.

Industrial Services
Pólo Tecnológico de Lisboa
R. Cupertino de Miranda, Lt 6, Piso 0 e 1
1600-546 Lisboa - Portugal
T. (351) 21 710 42 00
F. (351) 21 715 75 26

EC Type Examination

Acc. to Directive 97/23/EC & 2014/68/EU

Certificate nº: PTC16.00970.5046

Date: 2016.03.01

ame and address of MHI - M

Name and address of MHI - Mira Hidráulica Industriais, Lda
the manufacturer: Zona Industrial de Vagos - Lote 109, 3840-385
VAGOS
Portugal

SGS Portugal SA as a notified body for the scope of Pressure Equipment Directive 97/23/EC & 2014/68/EU, certifies that the Pressure Equipment stepsing, construction, inspection and assembly, is in compliance with the requirements of the Pressure Equipment Directive stated, acc. module B.

(E 1155

Assessed acc. to Directive 97/23/EC & 2014/68/EU:

Module B (Assembly)

Inspection Report nº: PTR1

PTR16.01107.5046

Equipment ID:

Assembly of Seamless Cylinders and Valves for Portable Fire Extinguisher 2 Kg CO2,

according with drawing C2-1 Rev.0 dated on 12-

12-2015

Model: C2; Class Fire: 34B; JX/CN

Design, construction and testing

Standards:

PED data:

EN3 (EN 3-7:2004 + A1:2007 and EN 3-9:2006)

PS: 170 bar TS: -30 / 60 °C

Vol: 3.0L Category: III Fluid/Group: Gr.2

PT: 60 bar (Assembly Leakage test)

Valid Until:

2026.03.01

Digitally signed by José

Fabião

Date: 2016-03-23 19:10Z

Technical Manager

IPAC acreditação

10009 Inspecção

INDIP813/4 (2016-01-27)

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf.

The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

SGSPAPER 16414563

