


Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



084 - PROD
17065

<p align="center">EU TYPE EXAMINATION CERTIFICATE – Production Type</p> <p align="center">In accordance with the requirements of Module B of the Pressure Equipment Directive 2014/68/EU</p>						<p align="center">Certificate N° 10/CN/2276-1 Rev. 1</p>																											
<p align="center">Manufacturer</p>		<p align="center">Name</p>		<p align="center">Ningbo Pingan Fire Fighting Equipment Manufacturing Co., Ltd</p>																													
		<p align="center">Address</p>		<p align="center">Dongxi Industrial Zone, Liangnong Town Yuyao City, Ningbo P.R. China</p>																													
<p>Concerned Productscope: Mobile Fire Extinguishers – Cylinder & Assembly</p>																																	
<table border="1"> <thead> <tr> <th>Type</th> <th>Model</th> <th>Diameter (mm)</th> <th>Volume V (liter)</th> <th>Design Temp. TS (°C)</th> <th>Design pressure PS (bar)</th> <th>Test Pressure PT (bar)</th> <th>Drawing</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Dry Powder</td> <td>MFTZL25</td> <td rowspan="2">255</td> <td>29</td> <td rowspan="3">-20/+60</td> <td rowspan="3">17</td> <td rowspan="3">24.5</td> <td rowspan="2">TA25-00</td> </tr> <tr> <td>MFTZL30</td> <td>34</td> </tr> <tr> <td>MFTZL50</td> <td>58</td> <td rowspan="2">TA50-00</td> </tr> <tr> <td>Foam</td> <td>MJPTZ50</td> <td>305</td> <td>63</td> <td>+5 / +60</td> </tr> </tbody> </table>								Type	Model	Diameter (mm)	Volume V (liter)	Design Temp. TS (°C)	Design pressure PS (bar)	Test Pressure PT (bar)	Drawing	Dry Powder	MFTZL25	255	29	-20/+60	17	24.5	TA25-00	MFTZL30	34	MFTZL50	58	TA50-00	Foam	MJPTZ50	305	63	+5 / +60
Type	Model	Diameter (mm)	Volume V (liter)	Design Temp. TS (°C)	Design pressure PS (bar)	Test Pressure PT (bar)	Drawing																										
Dry Powder	MFTZL25	255	29	-20/+60	17	24.5	TA25-00																										
	MFTZL30		34																														
	MFTZL50	58	TA50-00																														
Foam	MJPTZ50	305		63	+5 / +60																												
<p>Applicable Standard : EN1866-1 : 2007 & EN1866-2 : 2014</p> <p>Reference technical File: PED PA001 Rev.1</p>																																	
<p>The manufacturer is allowed to affix the «CE» mark followed by the notified body n° to the approved equipment under the conditions described in article 19 of the Directive and only if the requirements stated in module C2 are fully met.</p> <p align="center">The approval is valid until 18/10/2030</p>																																	
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/EU, certifies that the design of these pressure vessels conforms to the relevant requirements of the EN1866-2 standard and of the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.</p>																																	
<p>Approval Date : 01/03/2021</p>		<p>Name : B. NEVE, ir</p>			<p>Position : General Manager</p>																												
<p>Notified body identification number :</p>		<p>0029</p>			<p>Signature</p> 																												
<p>Third Party Authority :</p>		<p>APRAGAZ VZW / ASBL</p>																															
<p>Third Party Authority reference :</p>		<p>12419P000</p>																															